



EU TYPE EXAMINATION CERTIFICATE – Design Type In accordance with the requirements of Module B of the Pressure Equipment Directive 2014/68/EU		Certificate N° 08/IL/1627-2-REV 0
Manufacturer	Name	Lehavot Production & Protection (1995) Ltd.
	Address	Kibbutz Lehavot Habashan 12125 (Upper Galilee) Israel
<p>Concerned Equipment : Kitchen Fire Suppression Systems</p> <p>Models: WCK-6 / WCK-9 / WCK-16 / WCK-20 / WCK-26 as described in the technical</p> <p>Capacities : 7.5 L / 11.25 L / 22.5 L / 37.5 L</p> <p>Filling pressure: 15 bar (PS)</p> <p>Test pressure : 35 bar (PT)</p> <p>Use temperature range: min. 0°C / max. +49°C</p>		
<p>The manufacturer is allowed to affix the “CE” mark to approved equipment in the conditions described in the Directives and only if the requirements stated in module D are fully complied with.</p> <p>The approval is valid until 05/01/2029</p>		
<p>APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive, certifies that the design of these pressure assembly are conforms to the EN 16282-7, and following technical requirements of: EN 3-8 and EN 1866-2 standards on basis of the documentation and samples supplied for review and approval.</p>		
Date : 03/12/2018	Name : Ch. Leplat	Position General Manager
Notified body identification number :	0029	Signature To be signed at the next certification office
Notified body stamp :	APRAGAZ Belgium Inspecting Authority	
Notified body reference :	P9249/PED01	