



Chaussée de Vilvorde, 156  
Vilvoordsesteenweg 156  
B-1120 Bruxelles/Brussel  
Tel.: 32 (0)2 264 03 60  
Fax: 32 (0)2 268 89 58  
http://www.apragaz.com  
info@apragaz.com



<b>EU TYPE EXAMINATION CERTIFICATE – Production Type</b>		<b>Certificate N°</b> <b>08/IL/1627-2-REV 0</b>
In accordance with the requirements of Module B of the <b>Pressure Equipment Directive 2014/68/EU</b>		
<b>Manufacturer</b>	<b>Name</b>	<b>Lehavot Production &amp; Protection (1995) Ltd.</b>
	<b>Address</b>	<b>Kibbutz Lehavot Habashan 12125 (Upper Galilee) Israel</b>
<b>Concerned Equipment : Kitchen Fire Suppression Systems</b>		
<b>Models: WCK-6 / WCK-9 / WCK-16 / WCK-20 / WCK-26</b> as described in the respective technical files.		
<b>Capacities : 7.5 L / 11.25 L / 22.5 L / 37.5 L</b>		
<b>Filling pressure: 15 bar (PS)</b>		
<b>Test pressure : 35 bar (PT)</b>		
<b>Use temperature range: min. 0°C / max. +49°C</b>		
The manufacturer is allowed to affix the "CE" mark to approved equipment in the conditions described in the Directives and only if the requirements stated in module D are fully complied with. <b>The approval is valid until 05/01/2029</b>		
APRAGAZ, acting within the scope of its notification for the purpose of the European Council Directive, certifies that the design of these pressure assembly are conforms to the <b>EN 16282-7</b> , and following technical requirements of: <b>EN 3-8</b> and <b>EN 1866-2</b> standards on basis of the documentation and samples supplied for review and approval.		
Approval Date : <b>03/12/2018</b>	Name : <b>Ch. Leplat</b>	Position <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature
Notified body stamp :	<b>APRAGAZ</b> Belgium <b>Inspecting Authority</b>	
Notified body reference :	<b>P9249/PED01</b>	