

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170131-EX15622  
**Report Reference** EX15622 -20120215  
**Issue Date** 2017-JANUARY-31

**Issued to:** LEHAVOT PRODUCTION AND PROTECTION LTD  
Kibutz Lehavot Habashan  
1212500 Upper Gallile ISRAEL

**This is to certify that  
representative samples of**

WET-CHEMICAL-SOLUTION EXTINGUISHING SYSTEM  
UNITS-PRE ENGINEERED

WCK Series, 6, 9, 16, 20 and 26 Liter capacity, stored-pressure extinguishing system units. Unit is designed to discharge wet chemical solution from fixed nozzles for the extinguishment of fires in cooking appliances, hoods, plenums, filters, and ducts used for the ventilation of restaurant cooking equipment when such fires originate in the entrance of the ventilating equipment. For use at temperatures from +32 to +120°F. Operated by automatic means with manual back up. Includes the protection of deep fat fryers, griddles, range tops, upright broilers, chain broilers, electric char broilers, rock char broilers, natural charcoal char broilers, natural wood char broilers, gas radiant char broilers and woks.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 300 Fire Testing of Fire Extinguishing Systems for Protection of Restaurant Cooking Areas and UL 1254 Pre-Engineered Dry Chemical Extinguishing System Units  
The products covered by this certificate are for use in accordance with the National Fire Protection Association Standard for Wet Chemical Extinguishing Systems, NFPA 17A and Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, NFPA 96



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20170131-EX15622  
**Report Reference** EX15622 -20120215  
**Issue Date** 2017-JANUARY-31

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

